EmaZys Technologies

PV Analyzer Z200 Disconnect Report

Basic information

Test carried out by: EmaZys
Instrument operator: TEAM
PV site address: Odense
PV string: Top si
Date: 22-10-2018
Time: 14:36:46

Number of PV modules in string: 8

Instrument Name: Z200-R2E000118003

Installed software version: 3.6.1

Results

Entered cable capacitance:	80.0 pF/m
Length of cable to positive terminal:	$12.0 \mathrm{m}$
Length of cable to negative terminal:	$25.0 \mathrm{m}$
Capacitance measured from the positive terminal:	$2.6~\mathrm{nF}$
Capacitance measured from the negative terminal:	$5.2~\mathrm{nF}$
Low frequency norm (+ terminal):	$924.0~\mathrm{k}\Omega$
Low frequency norm (– terminal):	$910.0~\mathrm{k}\Omega$
Position	4.1

Disconnect Test:

This function searches for the position of a disconnect in the cables connected to the PV string. The result is given as a position counting from the PV_+ terminal.

Fault in modules between 3 and 5.

Field Notes:

Final Comments: